

## Standard Components - Room Data Sheet

<b>Room Name</b>	<b>Behavioural Assessment Room</b>	<b>Room Number: BAR_16m<sup>2</sup></b>
<b>Revision No.</b>	01	
<b>Last modified</b>	29/08/2017	
<b>BRIEFING</b>		
<b>Briefed Area</b>	16m <sup>2</sup>	
<b>Hours of Operation</b>	<i>Available 24 Hours</i>	
<b>Occupancy</b>	<i>1 patient, 1-10 staff,</i>	
<b>Acoustics</b>	<i>Sound attenuation level high. Acoustic privacy is required.</i>	
<b>Location and Relationships</b>	Adjacent to triage in ambulance reception / resuscitation cubicles & patient bays. Ideally an ensuite would be located adjacent to the room.	
<b>Remarks</b>	A Behavioural Assessment Room is used for assessing and managing emergency department patients exhibiting aggression which places themselves or others at risk of harm.	
<b>Description / Special Requirements</b>	Medical services are to be provided within a lockable cupboard. A storage area for restraints is to be provided out of sight / within a lockable cupboard. Door hardware should allow for free exit. All fittings, fixtures and hardware is to be of an anti-ligature type. Furniture should either be permanently fixed or of sufficient bulk to prevent use as a weapon. Air-Conditioning to support up to 10 people. An external outlook is desirable, and the design should maximise natural light. All glazing should be toughened laminated Grade A safety glass. An internal observation window is optional according to layout; a second room egress door is required.	
<b>SERVICES</b>		
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = Yes
<b>Air</b>	AIR-CONDITIONING = Yes	AIR-CONDITIONING: hepa filtered = No
	AIR-CONDITIONING: positive pressure = No	AIR-CONDITIONING: negative pressure = No
	EXHAUST: room exhaust = No	VENTILATION = No
<b>Lighting</b>	LIGHTING: down-lights, dimmable, flush with ceiling, tamper proof, anti-ligature = Yes	
	LIGHTING: fluorescent, flush with ceiling, tamper proof, anti-ligature = Yes	
	LIGHTING: indirect = Yes	
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes	

## Room Fabrics

AHFG code	Description	Comments
CLFS-006	CEILING: Plasterboard, flush set, suspended. Paint, acrylic, washable.	
DWGL-025	DOOR: 1100mm clear opening single leaf, observation panel, solid core/ safety glass. Paint, acrylic, washable.	2100mm height. Egress door, staff use, lock set, anti-ligature door hardware.
DWGL-033	DOOR: 1400mm clear opening, one and half leaf, observation panel, solid core/ safety glass. Paint, acrylic, washable.	2100mm height. Free to exit, anti-ligature door hardware.
DWGL-073	DOOR: 880 mm clear opening, single leaf, observation panel, solid core/safety glass. Paint, acrylic, washable.	to optional ensuite, dependent on layout. 2100mm height. 910mm c/o, single leaf, observation panel, solid core/safety glass, lockable from outside; anti-ligature door hardware.
DWOB-006	OBSERVATION: Internal window, alum frame /safety glass, double glazed, integral venetian blind. Powdercoat.	optional, dependent on layout.
DWOB-013	OBSERVATION: Through door/s, safety glass, double glazed with integral venetian blind. Powdercoat.	blind control to corridor side.
DWPR-004	DOOR PROTECTION: Protection plate, to 900 AFFL, PVC, pre-finished.	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
DWWD-007	BLIND: Venetian, integral	to all windows and vision panels
DWWD-010	CONTROL: venetian blind, remote	
DWWH-005	WINDOW: Double glazed with integral venetian blind, powdercoat.	optional, preferred.
FLSK-010	SKIRTING: Vinyl, floor vinyl coved, 150H, pre-finished.	
FLVY-007	FLOOR FINISH: Vinyl, seamless, coved, standard slip resistant	
WLPR-002	WALL PROTECTION: Bed protection wall panel, composite, laminate finish. Pre-finished.	full height
WLWA-004	WALL FINISH: Paint, acrylic, washable	walls should be of robust construction and resistant to damage by persons who may kick, punch or throw items against the walls.
WLWA-020	WALL FINISH: Vinyl 1500 AFFL	

## Fittings, Furniture & Equipment (FF&E) Items

AHFG code	Description	Group	Qty	Comments
FIHR-019	BRACKET: for suction bottle	1	1	in lockable cupboard
FIJO-131.1	CUPBOARD: Special. Recessed, single door, adj. shelves, lockable	1	1	recessed into wall cavity, incorporating medical services panel and bed protection wall panel, composite, laminate finish, pre-finished, anti ligature hardware.

## Engineering Services

AHFG code	Description	Group	Qty	Comments
ELBO-015	SWITCH: light, single	1	4-6	locate outside room

ELGP-105.1	GPO: single, on services panel (V)	1	2	on services panel, vertical orientation.
ELGP-122.1	GPO: emergency power, single, on services panel (V)	1	1	on services panel, vertical orientation.
ELGP-101	GPO: single, ceiling mounted	1	2	concealed, for CCTV camera
ELGP-110	GPO: single, wall mounted, cleaner	1	1	locate in corridor outside room
ELPR-001	BODY PROTECTED ELECTRICAL AREA	1	1	
ELPR-006	RCD: residual current device	1	1	on services panel
ITCL-004	BUTTON: nurse call, emergency	1	2	wall mounted, tamper proof, anti ligature
ITCL-006	BUTTON: nurse call, patient to staff	1	1	wall mounted, tamper proof, anti-ligature
ITCL-008	BUTTON: nurse call, staff assist	1	2	wall mounted, tamper proof, anti-ligature
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	on services panel
ITSE-002	ALARM: duress	1	2	
ITSE-038	READER: access control, general	1	1	card reader, wall mounted, tamper proof, anti ligature
LIFX-001	LIGHT: night light, tamper proof	1	1	tamper proof, low level, dimmable, anti ligature
LIFX-010	LIGHT: bedhead light, tamper proof	1	1	tamper proof, high level, dimmable, anti ligature
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	on services panel
MGAS-062	OUTLET: suction, on services panel	1	1	on services panel
MGFP-004	FLOWMETER: oxygen	3	1	to services panel
MMBE-016	BED: patient, manual.	3	1	room layout to allow for bed position, mental health bed optional.
MMGE-002	ADAPTER: suction	3	1	to services panel
MMGE-019.1	CHAIR: staff	3	1	mental health furniture
MMGE-100	SUCTION BOTTLE	1	1	on bracket, located in lockable cupboard
MMSP-025	SERVICES PANEL: special	1	1	concealed in lockable cabinet